

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 40

Dated : 19.01.2023

It is certified that an inspection team headed by Dr. Ramchandrasingh Singh from Primary Health Centre, Dalsingh Sarai Inspected the **ST. STEPHEN'S SCHOOL**, Gospur Road, Dalsingh Sarai, on 17/01/2023 and found that the **ST. STEPHEN'S SCHOOL**, Gospur Road, Dalsingh Sarai has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the State Govt.

The above valid for a period of 2023 - 24.

Signature with Seal : Ramchandrasingh 19/1/23

Name : Dr. Ramchandrasingh

Designation : Incharge Medical Officer.

प्रभारी चिकित्सा स्टाफ़ नाम

प्रभारी चिकित्सा स्टाफ़ दस्तावेज़

To,

The Secretary

St. Stephen's School

Gospur Road, Dalsingh Sarai

Samastipur, Bihar

Primary Health Center, Dalsingh Sarai

TO WHOM IT MAY CONCERN

This is to certify that after proper physical inspection of Health and Sanitary Condition of St. Stephen's School premises, Gospur Road, Dalsingh Sarai, Distt- Samastipur, Bihar is found good. The water has been found safe for drinking/cooking.

Following are our finding :-

TOILET AND WASH ROOMS :-

	Boys	Girls	Teachers	Guests
Urinal	15	24	08	02
Lavatories	15	24	06	02
Wash Basin	20	20	04	02

DRINKING WATER FACILITIES

- Sources of water :- One deep Boring
- Water Tap :- 40
- Over Head Tank :- 5 x 2000 Ltr.
- Mineral Water Plant (RO) :- 500 Ltr./Hrs
- Mineral Water Tank (RO) :- 1 x 2000 Ltr. , 1 x 500 Ltr. = 2500 Ltr.
- Mineral Water Tap (RO) :- 11

Latrine/Lavatories/Urinals constructed in the School premises are of hygienic norms.

Date:- 19/01/2023

Ramchandrase Singh
19/1/23
Medical Officer

P.H.C विकास परामिक स्तर
मुख्य अधिकारी नामित सरकार

Government of Bihar
Public Health Engineering Department

DISTRICT :- SAMASTIPUR

DIVISION :- SAMASTIPUR

MONTH:- JUNE 2023

S.N.	BLOCK	PANCHAYAT	VILLAGE	WARD	LOCATION OF SOURCE	PARAMETERS										REMARKS	
						pH	TURB.	EC	TDS	TH	Ca	Mg	Cl	Alka	NO ₃	T.COLI	
1	DALSINGHSARAI	DALSINGHSARAI	GOSPUR ROAD	16	ST.STEPHEN S SCHOOL	7.4	1	140	91	75	18	7	10	56	BDL	-VE	
Acceptable Limit as per BIS 10500/2012						6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	75mg/l	30mg/l	250mg/l	200 mg/l	45mg/l		-
Permissible Limit* in absence of alternate source as per BIS 10500/2012						NR	5 NTU	-	2000 mg/l	600 mg/l	200/m g/l	100/mg/l	1000 mg/l	600 mg/l	NR		-

Report 20.06.23
CHEMIST

23/6/23
EXECUTIVE ENGINEER
Executive Engineer
P.H. Div, Samastipur