

Primary Health Center, Dalsingh Sarai

TO WHOM IT MAY CONCERN

This is to certify that after proper physical inspection of Health and Sanitary Condition of St. Stephen's School premises, Gospur Road, Dalsingh Sarai, Distt- Samastipur, Bihar is found good. The water has been found safe for drinking/cooking.

Following are our finding :-

TOILET AND WASH ROOMS :-

	Boys	Girls	Teachers	Guests
Urinal	24	30	08	02
Lavatories	20	30	06	02
Wash Basin	30	30	04	02

DRINKING WATER FACILITIES

- Sources of water :- One deep Boring
- Water Tap :- 116
- Over Head Tank :- 4 x 2000 Ltr, 2 x 1000 Ltr, = 10,000 Ltr
- Mineral Water Plant (RO) :- 500 Ltr./Hrs
- Mineral Water Tank (RO) :- 1 x 2000 Ltr. , 1 x 1000 Ltr. 1 x 500 Ltr= 3500Ltr.
- Mineral Water Tap (RO) :- 14

Latrine/Lavatories/Urinals constructed in the School premises are of hygienic norms.

Date:- 02/06/2026

Medical Officer

P.H.C
प्रभारी चिकित्सा पदाधिकारी
प्राथमिक स्वास्थ्य केन्द्र, दलसिंहसराय

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 319

Date : 10/06/26

It is certified that an inspection team headed by Dr. Mohammad Naushad
Anwer (MDIC) PHC Dalsingsarai (Name of Officers
with designation) from PHC (Name of
Department/Office) inspected the ST. STEPHEN'S SCHOOL, GOSPUR
ROAD, DALSINGARAI, SAMASTIPUR, BIHAR (Name & Address of
the School) on 02.06.2026 and found that the ST. STEPHEN'S SCHOOL
GOSPUR ROAD, DALSINGARAI (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of June 2026 - March 2027

Signature with Seal :

NM
26/6/26
प्रभारी चिकित्सा पदाधिकारी
सामाजिक स्वास्थ्य केंद्र, दलसिंगसराय

Name : _____

Designation : _____

To,

The Secretary
St. Stephen's School, Gaspur Road,
Dalsingsarai, Samastipur, Bihar - 848114.

(Name & Address of the Institution)

**Government of Bihar
Public Health Engineering Department**

DISTRICT :- SAMASTIPUR			DIVISION :- SAMASTIPUR							MONTH:-JUNE 2026					
S.N.	BLOCK	WORD	LOCATION OF SOURCE	PARAMETERS											REMARKS
				pH	TURB	EC	TDS	TH	Ca	Cl	Mg	Alka.	Fe	T.COLI	
1	DALSINGH SARAI	16	ST.STEPHEN'S SCHOOL	7.0	1	155	101	48	18	16	9	64	0.1	-Ve	
Acceptable Limit as per BIS 10500/2012				6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	75 mg/l	250mg/l	30 mg/l	200 mg/l	1.0mg/l	-	
Permissible Limit* in Absence of Alternate source as per BIS 10500/2012				NR	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	1000 mg/l	100 mg/l	600 mg/l	NR	-	

Soni
11/06/26
Chemist / Lab Assistant
P.H. Division Samastipur

